

ADDENDUM NO. 4
TO THE
DRAWINGS AND SPECIFICATIONS
FOR THE
ROCKPORT ROAD PHASE 2
(COUNTRYSIDE LANE TO GRAHAM DRIVE)
PW2014-200

ISSUED FROM: CITY HALL AT THE SHOWERS BUILDING
Post Office Box 100
401 North Morton Street
Bloomington, Indiana 47404

ISSUE DATE: April 30, 2014

Bid DATE: April 30, 2014

This Addendum No.4 to the drawings and specifications shall supplement, amend and become a part of the bidding documents, plans, and specifications. All bids and construction contracts shall be based on these modifications to the original contract documents.

ITEM NO. 1: ROCKPORT ROAD PAVING MATERIAL:
HERE IS A COPY OF INFORMATION I JUST RECIEVED AND SHOULD
BE LOOKED AT, SORRY FOR THE LATE ADDENDUM LOOKING
FORWARD TO ALL THAT BID.

I discussed the pavement for Rockport Road with Adrian this morning. We concluded that Type B HMA is acceptable in lieu of QC/QA as indicated on the plans. Please distribute the following notification to the bidders:

The following materials may be substituted for the materials noted in the plans:

HMA Surface, Type B substituted for QC/QA HMA, 2, 70, Surface, 9.5 mm

HMA Intermediate, Type B substituted for QC/QA HMA, 2, 70, Intermediate, 19.0 mm

HMA Base, Type B substituted for QC/QA HMA, 2, 64, Base, 25.0 mm

Douglas A. Valmore, P.E.

	<p>CERTIFIED BY: _____</p> <p>ADRIAN REID CITY ENGINEER CITY OF BLOOMINGTON, IN</p>
--	--

Acknowledge receipt of the addendum by submitting a signed copy with your bid proposal.

RECEIVED BY: CONTRACTOR (FIRM AND ADDRESS)

SIGNATURE: _____

DATE: _____

PRINTED NAME: _____

TITLE: _____