

## Notes from Fairview pre-bid meeting

Q: If bidder has submitted a non-discrimination plan in the last 6 months, do they need to do it again?

A: Only if that submission didn't include the recent updates with additional non-discrimination groups.

Q: Special conditions say "seed and straw" but elsewhere it says "sod" which is it?

A: Sod

Q: Is concrete 4000 or City spec Class A?

A: Class A

Q: Is two-way traffic to be maintained at all times?

A: At least one-way to be maintained, will require flaggers. Okay to redirect with detours between blocks with proper signage.

Q: Are bidders responsible for asphalt work?

A: Yes

Q: Are bidders responsible for any striping?

A: No

Q: Is a performance bond required?

A: Yes

Q: What is completion date?

A: 90 days from April 1st. Can start before April 1st if desired and 90 day period won't start until April 1st.

Q: Do bidders have to price items that don't apply to the job. Unit price sheet currently says Rockport Rd

A: Everything on unit price sheet should be applicable, Rockport in name was an oversight.

Q: Has the City met its legal requirement for advertising?

A: Yes

Q: Do bidders have to conform to MUTCD for signs, including any ped detour signs?

A: Yes

Q: Do bidders have to maintain pedestrian access even though there is no sidewalk currently?

A: Yes