

ADDENDUM NO. 1
TO THE
DRAWINGS AND SPECIFICATIONS
FOR THE
17TH STREET SIDEWALK IMPROVEMENTS
BETWEEN MAPLE STREET AND MADISON STREET

ISSUED FROM: CITY HALL AT THE SHOWERS BUILDING
Post Office Box 100
401 North Morton Street
Bloomington, Indiana 47404

ISSUE DATE: June 24,2016

Bid DATE: June 28,2016

This Addendum No.1 to the drawings and specifications shall supplement, amend and become a part of the bidding documents, plans, and specifications. All bids and construction contracts shall be based on these modifications to the original contract documents.

ITEM NO. 1: THE CONTRACTOR WILL BE RESPONSIBLE FOR TAKING THE FIVE COMMUNICATION POLES LEFT BEHIND AFTER THE UTILITIES WERE RELOCATED ONTO THE NEW POLES AS PART OF THE CLEARING PROCESS.

ITEM NO. 2: THE WALL DETAIL FOR SMOKIN JACKS HAS BEEN ATTACHED WITH THE ADDENDUM. THE PROPERTY OWNER WILL PROVIDE THE LIMESTONE WHICH IS 4 INCH WIDE STACKING BASE AND A 11 OR 12 INCH CAP DEPENDING ON WHAT WILL BE NEEDED FOR A ONE INCH OVERHANG ON THE FRONT SIDE OF THE WALL AND THE CONTRACTOR IS TO PROVIDE ALL OTHER NECESSARY MATERIALS AND LABOR. THE PROPERTY OWNER NEEDS INFORMATION ABOUT THE SQUARE FOOTAGE OF LIMESTONE AND THE CAP AS EARLY AS POSSIBLE AND HE WILL HAVE IT CUT AND STAGED ONSITE.

ITEM No. 3: PER CONVERSATIONS WITH CBU, THE MANDREL PULLING COULD BE DONE AFTER THE WAIT PERIOD. ONLY THE MANHOLES NEED TO BE VACUMED TESTED.

ITEM No. 4: CBU ALSO REQUESTED A CASTING CHANGE: ALL 7030 M4 GRATE AND T1 BACK TO BE CHANGED TO 7505 M3 GRATE AND T3 BACK. STRUCTURE #113 TO BE CHANGED TO A TYPE C AND A 7565 M2 GRATE AND T1 BACK.

ITEM No. 5: THE CBU SPECIFICATION CONSTRUCTION HANDBOOK IS ON THE WEB PAGE ABOVE THE SPOT LIGHTED WEBPAGES BID AND QUOTE OPPORTUNITIES

ITEM No. 6: A NEW UNIT PRICE SHEET IS ATTACHED AND INCLUDED WITH THE ADDENDUM. THE NEW UNIT PRICE SHEET SHOULD BE COMPLETED AND SUBMITTED WITH THE SIGNED ADDENDUM AS A PART OF THE BID PACKAGE SUBMITTAL.

