



**INVITATION TO BID - #2016-ESD-SOLAR**  
**Solar Panel Installation and Roof Replacement Project**

**Addendum #1**

Question Number	RFP Section (if applicable)	Question/Clarification	Additional Information/Responses
1		Is it acceptable to submit a bid for "Project B" and not "Project A", and vice versa?	Yes, it is acceptable to submit for only one or the other of the solar projects.
2		Is it acceptable to submit a bid for the PV installation only in "Project A", or is it required to submit roof replacement as well?	Our Legal Department has a strong preference for Project A and the roof replacement to be bid together.
3		What are the limiting factors for PV system size in "Project A"? Is there cap on the budget? Are the Municipal buildings subject to Net-Zero Metering?	We are looking for a per-watt price estimate and a maximum budget based on the assumption that we will have the budget to fill up the entire roof of Lot 1 at City Hall.
4		Are the Municipal buildings subject to Net-Zero Metering?	Yes, city buildings are eligible for net metering if the system is smaller than 1 megawatt; however, my guess is that both City Hall and BPD headquarters will directly use the energy they produce.
5		Will utility bills be made available for sizing the PV system if Net-Zero metering is a design factor?	Yes, we will make these available at the pre-bid meeting on October 11.

**BIDDER MUST ACKNOWLEDGE THIS AMENDMENT BY SIGNING BELOW AND ATTACHING THE SIGNED AMENDMENT TO THEIR BID FORM**

Company Name \_\_\_\_\_

Contact Person \_\_\_\_\_

Signature \_\_\_\_\_

Date \_\_\_\_\_