

ADDENDUM NO. 1
TO THE
DRAWINGS AND SPECIFICATIONS
FOR THE

MADISON STREET SIDEWALK (3RD STREET TO PROSPECT STREET))
PW 09-24

ISSUED FROM: CITY HALL AT THE SHOWERS BUILDING
Post Office Box 100
401 North Morton Street
Bloomington, Indiana 47404

ISSUE DATE: November 19, 2009

Bid DATE: November 20, 2009

This Addendum No.1, to the drawings and specifications shall supplement, amend and become a part of the bidding documents, plans, and specifications. All bids and construction contracts shall be based on these modifications to the original contract documents.

ITEM No. 1:

Shall include changes and modifications as depicted and listed on the attached addendum sheets provided by Bledsoe, Riggert and Guerrettaz, with regard but not limited to the clarification of detail notes as depicted on the attached sheets.

ITEM No. 2:

Bids will be due at 10:30a.m. local time on November 20, 2009 at 401 North Morton Street, Suite 130, Bloomington, Indiana 47404. This consideration is being given for any bidding changes needed to accommodate this addendum.

	 CERTIFIED BY: JUSTIN D. WYKOFF CITY OF BLOOMINGTON STATE OF INDIANA
--	---

Acknowledge receipt of the addendum by submitting a signed copy with your bid proposal.

RECEIVED BY: CONTRACTOR (FIRM AND ADDRESS)

SIGNATURE: _____

DATE: _____

PRINTED NAME: _____

TITLE: _____

BRG Project No. 6613

November 18, 2009

South Madison Street - Prospect to Third Sidewalk Improvements

Addendum No. 1


Sheet C301

1. Revise Plan Note 9 to read, "Concrete Pavement 8" Thick - Refer to detail."

Sheet C601

1. Revise Detail 5/C601 as indicated in the attached sketch ADD1-C1
2. Contractor to install a self leveling polyurethane, neoprene, or vinyl sealant on all expansion joints.

File - Project No. 6613



5
C601

CONCRETE PAVEMENT - 6/8" THICK

Bledsoe Riggert Guerrettaz
LAND SURVEYING • CIVIL ENGINEERING
1351 West Tapp Road
Bloomington, Indiana 47403
p: 812-336-8277
f: 812-336-0817

SOUTH MADISON STREET -- PROSPECT TO THIRD
SIDEWALK IMPROVEMENTS

- Addendum
- ESI
- PR
- RFI Response

Project No.:
6613

Date:
11/18-09

Drawing No.:

ADD1-C1