

**ADDENDUM NO. 1**  
**TO THE**  
**DRAWINGS AND SPECIFICATIONS**  
**FOR THE**  
**South Walnut Street Sidewalk**

**Issued From:** The City of Bloomington  
Planning and Transportation Department  
Post Office Box 100  
401 North Morton Street, Suite #130  
Bloomington, Indiana 47402

**Issue Date:** November 8<sup>th</sup>, 2017

**Letting Date:** November 13<sup>th</sup>, 2017

This Addendum No.1 to the drawings and specifications shall supplement, amend and become a part of the quote documents, plans, and specifications for the South Walnut Street Sidewalk. All quotes and construction contracts shall be based on these modifications to the original contract documents. Quoters shall acknowledge receipt of this Addendum on the Quote Form. Failure to do so may subject the Quoter to disqualification.

**Item No. 1: Questions and Answers**


- (Q) The contract book on this project states that it is to start within 15 days of award and to be complete within 60 days. The 60 days isn't an issue but could dates be added that would allow spring construction rather than winter?
- (A) We anticipate issuing the NTP in December, after award, as per the contract documents. However, and in accordance with SS 101.73, no work days will be charged during the months of December, January, February, or March. This will allow the contractor to start early if they choose to do so.
- (Q) The project has a quote bond form in the quote packet and the instructions to bidders but does not have any requirements for the quote bond. Is a quote bond required? If so please provide instructions for the quote bond.
- (A) A quote bond is not required for this project.

(Q) Item 8 - Subgrade Treatment, Type IB is a 14 in chemical soil modification. Due to the equipment size and cost it would not practical for this application and the same goes for the other chemical subgrade treatment types. Subgrade treatment Type IC is generally used for this application and would also be the most cost effective.

(A) Subgrade Type IC shall be used for this project. See the Corrected Schedule of Items included as part of this addendum.

(Q) The project has a "Proposal Schedule of Items (Unit Prices)" in the quote packet will payment be based on the final in place quantities multiplied by these unit prices?

(A) Yes, Payment will be made in accordance to Standard Specifications 109. Partial Payments and Final Payment will be based upon the Schedule of Items and the final in-place quantities (work completed).

	<p><b>CERTIFIED BY:</b> <u></u></p> <p>NEIL KOPPER INTERIM TRANSPORTATION &amp; TRAFFIC ENGINEER CITY OF BLOOMINGTON, IN</p>
--	--

Acknowledge receipt of the addendum by representing it on the Quote Form in Section B and submitting a signed copy with your quote proposal.

RECEIVED BY: CONTRACTOR (FIRM AND ADDRESS)

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

SIGNATURE: \_\_\_\_\_

DATE: \_\_\_\_\_

PRINTED NAME: \_\_\_\_\_

TITLE: \_\_\_\_\_



**Proposal Schedule of Items (Unit Prices)**

Project Title: South Walnut Street Sidewalk

LINE	ITEM	DESCRIPTION	Approximate Quantity and Units	UNITS	UNIT PRICE	QUOTE AMOUNT
001	105-06845	CONSTRUCTION ENGINEERING	1 Lump Sum		-	-
002	110-01001	MOBILIZATION AND DEMOBILIZATION	1 Lump Sum		-	-
003	201-52370	CLEARING RIGHT OF WAY	1 Lump Sum		-	-
004	203-02000	EXCAVATION, COMMON	100 CYS		-	-
005	203-02070	BORROW	63 CYS		-	-
006	205-06933	TEMPORARY INLET PROTECTION	1 EACH		-	-
007	205-06937	TEMPORARY SILT FENCE	634 LFT		-	-
008	207-09935	SUBGRADE TREATMENT, TYPE IC	136 SYS		-	-
009	211-09264	STRUCTURE BACKFILL, TYPE 1	3 CYS		-	-
010	303-01180	COMPACTED AGGREGATE NO. 53	75 TON		-	-
011	304-07494	WIDENING WITH HMA, TYPE C	40 TON		-	-
012	306-08034	MILLING, ASPHALT, 1 1/2 IN.	208 SYS		-	-
013	402-07452	HMA WEDGE AND LEVEL, TYPE C	18 TON		-	-
014	604-02007	SIDEWALK, CONCRETE, RECONSTRUCT	36 SYS		-	-
015	604-06070	SIDEWALK, CONCRETE	336 SYS		-	-
016	605-06120	CURB, CONCRETE	272 LFT		-	-
017	611-08232	MAILBOX ASSEMBLY, SINGLE RESET	1 EACH		-	-
018	616-06405	RIPRAP, REVETMENT	1 TON		-	-
019	616-12246	GEOTEXTILE FOR RIPRAP TYPE 1A	3 SYS		-	-
020	621-06567	WATER	1 kGAL		-	-
021	621-06575	SODDING, NURSERY	306 SYS		-	-
022	715-05149	PIPE, TYPE 2, CIRCULAR, 12 IN.	8 LFT		-	-
023	715-46000	PIPE END SECTION, DIAMETER 12 IN.	1 EACH		-	-
024	720-45270	PIPE CATCH BASIN, 18 IN.	1 EACH		-	-
025	801-06640	CONSTRUCTION SIGN, A	4 EACH		-	-
026	801-06645	CONSTRUCTION SIGN, B	10 EACH		-	-
027	801-06775	MAINTAINING TRAFFIC	1 LS		-	-
028	NA	SIGN, RELOCATE	5 EACH		-	-

**TOTAL QUOTE:** \_\_\_\_\_