

ADDENDUM NO. 2
TO THE
DRAWINGS AND SPECIFICATIONS
FOR THE
South Mitchell Street Sidewalk

Issued From: The City of Bloomington
Planning and Transportation Department
Post Office Box 100
401 North Morton Street, Suite #130
Bloomington, Indiana 47402

Issue Date: November 20, 2018

Letting Date: November 27th, 2018

This Addendum No.2 to the drawings and specifications shall supplement, amend and become a part of the Bid documents, plans, and specifications for the South Mitchell Street Sidewalk. All Bids and construction contracts shall be based on these modifications to the original contract documents. Bidders shall acknowledge receipt of this Addendum on the Bid Form. Failure to do so may subject the Bidder to disqualification.

Item No. 1: Questions and Answers

(Q) The contract book on this project states that it is to start within 15 days of award and to be complete within 60 days. The 60 days isn't an issue but could dates be added that would allow spring construction rather than winter?

(A) We anticipate issuing the NTP in December, after award, as per the contract documents. However, and in accordance with SS 101.73, no work days will be charged during the months of December, January, February, or March. Work days will be charged starting April 1st 2019, but the contractor may start early if they choose to do so.

(Q) Regarding storm sewer castings, the INDOT specifications note that Neenah and East Jordan are acceptable. Do city specifications allow Neenah castings?

(A) All storm sewer materials and installation methods shall comply with City of Bloomington Utilities Specifications. These Specifications do not allow Neenah castings. Products from manufacturers not approved per these Specifications will not be accepted. See the attached **UNIQUE SPECIAL PROVISION** that is hereto added to and a part of this addendum.

**USP 06 CONSTRUCTION SPECIFICATIONS FOR CITY OF BLOOMINGTON UTILITIES -
WASTEWATER, WATER AND STORM PROJECTS**

All storm sewer materials and installation shall comply with current Construction Specifications for City of Bloomington Utilities - Wastewater, Water and Storm Projects. A copy of these construction specifications is available from the City of Bloomington Utilities website at <https://bloomington.in.gov/utilities/contractors>.

	<p>CERTIFIED BY: <u>Neil Kopper</u></p> <p>NEIL KOPPER INTERIM TRANSPORTATION & TRAFFIC ENGINEER CITY OF BLOOMINGTON, IN</p>
--	---

Acknowledge receipt of the addendum by representing it on the Quote Form in Section B and submitting a signed copy with your quote proposal.

RECEIVED BY: CONTRACTOR (FIRM AND ADDRESS)

SIGNATURE: _____

DATE: _____

PRINTED NAME: _____

TITLE: _____