



1. PROPER AIR GAP IS TWICE THE DIAMETER OF SUPPLY PIPING EX.— A 2" PIPE REQ. A 4" GAP.
2. FAILURE TO COMPLY WILL RESULT IN REVOCATION OF HYDRANT USAGE.
3. USAGE OF A HYDRANT WRENCH IS THE ONLY ACCEPTABLE MEANS OF OPENING AND CLOSING HYDRANTS.
4. MUST ONLY USE HYDRANTS DIRECTED FOR USE BY CBU REPRESENTATIVE.

CITY OF BLOOMINGTON UTILITIES ENGINEERING DEPARTMENT

APPROVED BY:
R. FIEDLER

DRAWN BY:
J. STEPHENS

FILE LOCATION:
I:\COMMON\STANDARD DRAWINGS\STD35.DWG

STANDARD
DETAIL
NUMBER

35

Date:
04/26/2017

FILL PIPE DETAILS FOR PORTABLE TANKS WITH AIR GAP
SEPERATION