



NOT TO SCALE

- *NOTES**
- (A) 36" HEIGHT FROM TOP OF NUT TO GROUND
 - (B) TYPICAL ILLUSTRATION ANY BACKFLOW PREVENTOR MUST BE INSTALLED PER MANUFACTURERS DIRECTION

STANDARD FIRE LINE DOUBLE CHECK VALVE
2" OR SMALLER DOMESTIC METER
INSTALLATION DETAIL

City of Bloomington Utilities Engineering Department
 JDR
 REVISED 03/31/2020
 Drawing File:
 I:\COMMON\STANDARD DRAWINGS\STD28.dwg

STANDARD
 DETAIL
 NUMBER 28