



CITY OF BLOOMINGTON UTILITIES

600 E Miller Drive, Bloomington, IN 47401

www.bloomington.in.gov/utilities



FINISHED WATER - PEAK DEMAND DAYS

2 year period: 01/01/2022 - 12/31/2023

Top 5 days for Peak Demand:

04/05/2022	19.50
08/22/2023	18.60
08/25/2023	18.50
08/31/2022	18.50
07/01/2022	18.40

Average: 18.70 MGD

Ratio: 62.33 %

Peak Capacity: 30 MGD
20,833 GPM

PWS ID # 525-3002

PWS Contact Info:

Development Projects Phil Peden (Engineer) 812-349-3634

Capital Projects Jane Fleig (Engineer) 812-349-3631

This document will be updated annually with the previous 2 years of data.
If you have any questions, please contact the Utilities Technician at 812-349-3676.