



CITY OF BLOOMINGTON UTILITIES

600 E Miller Drive, Bloomington, IN 47401

www.bloomington.in.gov/utilities

FINISHED WATER - PEAK DEMAND DAYS

2 year period:

01/01/2023 - 12/31/2024

Top 5 days for Peak Demand:

09/09/2024	19.30
08/28/2024	19.00
08/27/2024	18.90
08/22/2023	18.60
08/25/2023	18.50

Average:

18.86 MGD

Ratio:

62.87 %

Peak Capacity:

30 MGD
20,833 GPM

PWS ID #

525-3002

PWS Contact Info:

Development Projects

Caden Swanson (Engineer) 812-349-3653

Capital Projects

Jane Fleig (Engineer) 812-349-3631

This document will be updated annually with the previous 2 years of data.
If you have any questions, please contact the Utilities Technician at 812-349-3676.