

ADDENDUM NO. 1

JUNE 2, 2026

PREPARED BY SCHMIDT ASSOCIATES FOR:
BLOOMINGTON CONVENTION CENTER WAYFINDING & SIGNAGE
BLOOMINGTON MONROE COUNTY CONVENTION CENTER

This Addendum consists of 2 Addendum pages and 1 attachment pages totaling 3 pages.

Acknowledge receipt of this Addendum by inserting its number on the Bid Form. Failure to do so may subject the Bid to disqualification. This Addendum is part of the Contract Documents.

Bidder is encouraged to verify with reprographer of record all Addenda issued (do not rely exclusively on third party plan room services).

PART 1 - CHANGES TO PRIOR ADDENDA (NOT APPLICABLE)

PART 2 - CHANGES TO THE PROJECT MANUAL

Modifications described herein shall be incorporated in the Project Manual. All other Work shall remain unchanged.

2.1 DIVISION 10 – SPECIALTIES

A. Section 101400 “SIGNAGE”

1. MODIFY Subparagraph 2.9, A. as follows:

“A. Provide one of the following product applications:

1. Painted Aluminum Finish: Finish exposed aluminum surfaces scheduled to receive paint with a factory-applied Matthews Acrylic Polyurethane (MAP®) coating system.

a. Manufacturer: PPG Mathews Paint

- 1) Product: Mathews Acrylic Polyurethane (MAP), Specification MPC101.

b. Performance Requirements:

- 1) Exterior-grade, UV-resistant aliphatic acrylic polyurethane coating system.
- 2) Resistant to fading, chalking, moisture, abrasion, chemicals, and atmospheric pollutants.

- 3) Suitable for long-term exterior architectural and signage applications.
- c. Color and Sheen:
 - a) Colors as selected by Architect from manufacturer's full range.
 - b) Sheen to be satin unless otherwise indicated on Drawings
2. Baked-Enamel Finish: AA-C12C42R1x (Chemical Finish: cleaned with inhibited chemicals; Chemical Finish: acid-chromate-fluoride-phosphate conversion coating; Organic Coating: as specified below). Apply baked enamel complying with paint manufacturer's written instructions for cleaning, conversion coating, and painting.

PART 3 - CHANGES TO THE DRAWINGS (NOT APPLICABLE)

END OF ADDENDUM 1

AVAILABLE PROJECT INFORMATION

The following information is being made available to Bidders for informational purposes only and is not a part of the Addendum.

- A. Bidding RFI Responses Report



Better Foresight
 Better Insight
 Better On-Site
 317.263.6226
 Indianapolis | Louisville
 schmidt-arch.com

Bidding RFI Responses Report

2025-232.WAY
 Bloomington Convention Center Expansion and Renovation Wayfinding & Signage
 Prepared On: 6/2/2026

ID	Subject	Question	Response
BID-004	Wayfinding - Overall	<p>Overall</p> <ul style="list-style-type: none"> Is it acceptable to use standard sign paint (Matthews Acrylic Polyurethane) on everything instead of powder coating? 	<p>Response (Answered) from: Liam Keesling (Schmidt Associates)</p> <p>Remarks: Yes. See Addendum 1, 2.11 Division 10 - Specialties, Section 101400 SIGNAGE for additional information.</p>
BID-003	WF-401	<p>WF-401</p> <ul style="list-style-type: none"> Is the TV screen included in the signage scope, or is it provided by the digital signage contractor? 	<p>Response (Answered) from: Liam Keesling (Schmidt Associates)</p> <p>Remarks: Digital Signage Display for Exterior Monument Sign shall be included in Wayfinding Package.</p> <p>Interior digital signage display monitors are included in Construction Documents Package.</p>
BID-002	WF-402/403	<p>WF-402/403</p> <ul style="list-style-type: none"> What is the construction of the larger "P", "R", "E"s <ul style="list-style-type: none"> Is it push through acrylic? 	<p>Response (Answered) from: Liam Keesling (Schmidt Associates)</p> <p>Remarks: Directional Sign with Single-Sided Identifier Panel (typ. "P", "R", "E") Shall be a painted surface with painted letter.</p>
BID-001	WF-404	<p>There are concerns with the legibility of the lettering size with the perforation.</p> <ul style="list-style-type: none"> Is it acceptable to leave red areas unperforated and only perforate the black areas? This maintains text legibility while still offering wind relief Is it acceptable to fabricate an aluminum frame border for stability and mounting bracket? 	<p>Response (Answered) from: Liam Keesling (Schmidt Associates)</p> <p>Remarks: -It is acceptable to leave red areas unperforated. Only the areas painted black shall be perforated. -If additional stability is required for signage mounting hardware, provide along edge facing pole.</p>